

Tackle Slips/Trips/Falls



Stairs

Church/program:

Date:

Enter "x" under the Yes or No column for the following items:

	Yes	No	Actions Taken
Stair surfaces are covered with slip-resistant material.	_____	_____	_____
Stairs/treads have contrasting colors for visibility.	_____	_____	_____
Lighting is adequate at the base, top, and along the length and landings of staircases.	_____	_____	_____
Handrails contrast with the wall to which they are attached.	_____	_____	_____
Staircases 44" wide or less have at least one handrail.	_____	_____	_____
Staircases wider than 44" have a handrail on both sides.	_____	_____	_____
Handrails are at least 34-38" above nosing of treads or finished floor.	_____	_____	_____